



Ref. Certif. No.

FR_708125

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Power supply

Switch-mode Power Supply (built-in)

Name and address of the applicant

PULS GmbHElektrastr. 6,
81925 München
GERMANY

Name and address of the manufacturer

PULS GmbHElektrastr. 6
81925 München
GERMANY

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

Input: AC 100–240 V, 0,8–0,4 A, 50–60 Hz

Output: DC 24–28 V

1,5–1,2 A (below +60 °C)

1,1–0,95 A (at +70 °C)

Derate linearly between +60°C and +70°C

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

PIANO Series:
PIM36.241, PIM36.242

Additional information (if necessary may also be reported on page 2)

/

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

19TH0547-62368-1_0

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 12/03/2020

Signature: **Gilles LEMONNIER**
Certification Officer

ANNEX

Name and address of the factories:**PULS ELECTRONICS (SUZHOU) CO. LTD.**

No 1 Rui En Lane Xingpu Rd, SIP
Suzhou, Jiangsu, 215021 – CHINA

PULS INVESTICNI SRO

Prazska 5639
430 01 Chomutov – CZECH REPUBLIC



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 12/03/2020

Signature: 
Certification Officer

